


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. न.नि.को.(दक्षिण) जन.स्वा./2024/07

Dated : 08/04/2024

It is certified that an Inspection team headed by RICHA GAUTAM
(Name of Officers with designation) from **HEALTH OFFICER** (Name of Department/Office)
inspected the **NAGAR NIGAM KOTA SOUTH** (Name & Address of the school) on
11/4/2024 (date of inspection) and found that the **VIDHYANJALI ACADEMY,**
BANDHA DHARMPURA, BEHIND KHADE GANESH JI TEMPLE, KOTA RAJ.-324010 (Name
of school) has safe drinking water facilities for the students and members of staff of the
institution and is maintaining the hygienic sanitation condition In the school building &
the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **ONE YEAR**Signature with Seal: 

Name :

RICHA GAUTAM स्वास्थ्य अधिकारी
नगर निगम, कोटा दक्षिणDesignation : **HEALTH OFFICER.**Name & Address of the Office / Department :
NAGAR NIGAM KOTA SOUTH

To

PRINCIPAL

VIDHYANJALI ACADEMY,**BANDHA DHARMPURA,****BEHIND KHADE GANESH JI TEMPLE,****KOTA RAJ.-324010**

(Name & Address of the Institution)

The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



कार्यालय नगर निगम कोटा दक्षिण (राज०)

क्रमांक :- ननिको(द.)/जनस्वा./2024/07

दिनांक :- 08/04/2024

प्रमाण-पत्र

प्रमाणित किया जाता है कि विद्यांजली अकेडमी, बंधा धर्मपुरा रोड़, खड़े गणेश जी मंदिर के पीछे, कोटा, राजस्थान में स्थित है। उक्त विद्यालय का वातावरण स्वच्छ व साफ है तथा सफाई की अनुकूल व्यवस्था है। यह प्रमाण पत्र एक वर्ष के लिये मान्य होगा।

स्वास्थ्य अधिकारी
नगर निगम, कोटा दक्षिण
नगर निगम कोटा दक्षिण



OFFICE OF THE SENIOR CHEMIST

Public Health Engineering Department, Regional Laboratory, Kota
Test Report (Chemical & Bacteriological Examination of Water)

No. Lab./Tech.(Chem)/2023-24/ 1973

Date:- 22/2/24

To,

Director

District: kota

Vidhyanjali Academy Kota

Reference No- 0

Sample taken by- Vinod Mehra

Date of Receipt- 19-02-2024

Source	Permissible Value as Per I.S : 10500/2018		RO	
Location			Vidhyanjali Academy School campus	
Village/Town/City			kota	
Date of Collection			19-02-2024	
Date of Examination			19-02-2024	
Sample No	Desirable Limit	Permissible limit in absence of alternate	PC-170	
Note:- All results except pH are in mg/L				
pH	6.5 to 8.5	No relaxation	7.30	
Turbidity(NTU)	1	5	1.12	
Colour	5	15	-	
Odour	Agreeable	Agreeable	-	
Total Alkalinity	200	600	48	
Total Hardness (as CaCO ₃)	300	600	44	
Calcium Hardness (as CaCO ₃)	187	500	-	
Calcium	-	-	-	
Magnesium Hardness (as CaCO ₃)	-	-	-	
Magnesium	-	-	-	
Chloride(as Cl ⁻)	250	1000	24	
Iron	0.3	0.3	-	
Nitrate as(NO ₃ ⁻)	45	45	2.69	
Sulphate as(SO ₄ ⁻²)	200	400	-	
Fluoride	1.0	1.5	0.145	
Total Dissolved Solids	500	2000	117	
Conductivity	-	-	-	

REMARK-

Senior Chemist

PHED Reg. Laboratory Kota

No. Lab./Tech.(Chem)/2023-24/

Date:-

Copy To :

1. Chief Chemist, PHED Rajasthan, Gandhi Nagar, Jaipur

Senior Chemist

PHED Reg. Laboratory Kota